

June 3, 2009

MEADE CONSTRUCTION CO., INC.
JOHN MEADE
PO BOX 76
LODI WI 53555

Re: Description: SEWAGE TREATMENT APPARATUS (see also SEWAGE TANKS; STA-TANK/CONTAINER)
Manufacturer: MEADE CONSTRUCTION CO., INC.
Product Name: MICRO FAST 0.5, 0.75, 0.9 / PUMP
Model Number(s): 1200/800
(L.L. 50.25/50.25 IN., 24.13/15.93 GAL/IN.; 48 IN. MAX. DEPTH OF BURY)
Product File No: 20090158

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of June 2014.**

This approval is contingent upon compliance with the following stipulation(s):

- This tank may only be used when installed with the Bio-Microbics, Inc., High Strength or Micro Fast sewage treatment apparatus.
- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- This product must be installed in accordance with the manufacturer's printed instructions, product approval and the plan approval. If there is a conflict between the manufacturer's instructions and the plan approval, the plan approval will take precedence.
- **Also refer to the Commerce product approval stipulations for the sewage treatment apparatus, which may include: maximum daily wastewater flow, influent strength, maximum BOD5, and maintenance intervals.**

This approval supersedes the approval issued on 5/25/2004 under product file number 20040271. This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20040271.

As of May 15, 2008, a copy of a successful water tightness test report for this product must be AVAILABLE FOR INSPECTION AT THE MANUFACTURER'S PLANT prior to this product being used as a POWTS holding or treatment tank in Wisconsin.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST
Engineering Consultant--Plumbing Product Reviewer
Commerce; Safety & Buildings Div.; PO Box 2658; 201 W Washington Ave.; Madison WI 53703-2658
Phone: 608-266-0955; Fax: 608-283-7456
E-mail: Jean.MacCubbin@wisconsin.gov